

CERTIFICATE

15632 2005 14A

according to EN 15632-1:2009+A1:2014 &
EN 15632-3:2010+A1:2014

for

pre-insulated flexible non-bonded pipe system
with one or two plastic service pipes:

TERRENDIS® Single and Double Heating

by order of

TERRENDIS NV

This certificate is based on report 1619E5370 dated from 2020-04-29 and report 1628E5370 dated from 2020-05-13.

This certificate covers “TERRENDIS® Single and Double Heating” pipes those consist of one or two service pipes of peroxide cross-linked polyethylene (PE-Xa) with an oxygen diffusion barrier for each service pipe, a thermal insulation of polyolefine foam and a casing of high density polyethylene (HDPE).

“TERRENDIS® Single and Double Heating” pipes described above meet requirements given in EN 15632-1:2009+A1:2014 Cl. 5.1...5.5 & 7.2 and EN 15632-3:2010+A1:2014 Cl 4.5

Hemmingen, 2020-05-13



Thomas Grage
Managing Director



Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaeme.de

Reg. at
District Court
Hanover
HRB 207980



Sönke Kraft
Project Manager