

EU DECLARATION OF CONFORMITY

We, Terrendis NV, declare the published information in relation with the production and supply of Terrendis hyper flexible pre-insulated piping system is in conformity with the below stated standards and other related documents :

- EN 15632-1 & 3. This is certified by FFI (Fernwärme ForschungsIntitut – certificate 15632 2005 14A)

The cross linked PE-Xa carrier pipes used in the Terrendis pre-insulated Heating and Sanitary pipes are produced according the standards DIN 16992/3 and EN ISO 15875.

The sanitary pipes are covered by the following hygienic certificates for potable water:

- DVGW - DW8301CO0292 and DW8302CO0293
- WRAS - Approval Number 2312525 based on Test Report: 122300912-0001
- ACS Certificate of Sanitary Conformity : 20 MAT LY 186

The HDPE100 pipes used in the Terrendis pre-insulated Cool pipes are produced according the standards EN 12201 and are covered by the following hygienic certificates for potable water:

- DVGW – DW8136CM0297 and DW8141CL0537
- WRAS - Approval Number 240655045 based on Test Report: 24.19304
- ACS Certificate of Sanitary Conformity : 20 MAT LY 085
- SVGW Certificate number 0910K287

The closed-cell crosslinked polyolefin foam is hydrophobic with an absorption inferior to 1% in accordance with ISO 2896.

Terrendis NV is an ISO 9001-2015 certified and controlled company and its products are covered by a ten years warranty.



Pascal VERBEKE
Managing Director
Terrendis NV